

Fire-resistance test on fire collars protecting a concrete floor slab penetrated by services

Test Report

Author: Chris Wojcik
Report number: FSP 1789
Date: 27 March 2017

Client: IG6 Pty Ltd as trustee for the IG6 IP Trust

Commercial-in-confidence



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing

Inquiries should be address to:

Fire Testing and Assessments
NATA Registered Laboratory
14 Julius Avenue
North Ryde, NSW 2113
Telephone +61 2 9490 5444

Author
Infrastructure Technologies
14 Julius Avenue
North Ryde, NSW 2113
Telephone +61 2 9490 5500

The Client
IG6 Pty Ltd as trustee for the IG6
IP Trust
3 Skirmish Court
Victoria Point Qld 4165

Report Status and Revision History:

VERSION	STATUS	DATE	DISTRIBUTION	ISSUE NUMBER
Revision A	Draft for review	25/01/2017	CSIRO	FSP 1789
Revision B	Final for issue	27/03/2017	CSIRO and Client	FSP 1789

Report Authorization:

AUTHOR	REVIEWED BY	AUTHORISED BY
Chris Wojcik	Brett Roddy	Brett Roddy



27 March 2017

27 March 2017

27 March 2017

Use of this Report

Use of Reports – Testing

This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.

Excerpts of the Report may not be published.

Use of Reports – Consultancy

This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.

The Report must not be used as a means of endorsement without the prior written consent of CSIRO.

Copyright and disclaimer

© 2017 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

Contents

1	Introduction	5
1.1	Identification of specimen	5
1.2	Sponsor	5
1.3	Manufacturer	5
1.4	Test standard	5
1.5	Reference standard.....	5
1.6	Test number.....	5
1.7	Test date	6
2	Description of specimen	6
2.1	General.....	6
2.2	Dimensions	7
2.3	Orientation.....	7
2.4	Conditioning.....	8
3	Documentation	8
4	Equipment.....	8
4.1	Furnace	8
4.2	Temperature	8
4.3	Measurement system	8
5	Ambient temperature	9
6	Departure from standard	9
7	Termination of test	9
8	Test results	9
8.1	Critical observations	9
8.2	Furnace temperature.....	9
8.3	Furnace severity.....	10
8.4	Specimen temperature.....	10
8.5	Performance	10
9	Fire-resistance level (FRL)	11
10	Field of direct application of test results	11
11	Tested by	11
	Appendices	12
	Appendix A – Measurement location	12
	Appendix B – Photographs	13
	Appendix C – Furnace Temperature	17
	Appendix D – Installation drawings.....	22
	Appendix E – Specimen Drawings	25
	Appendix F – Certificates	27
	References	30

Fire-resistance test on fire collars protecting a concrete floor slab penetrated by services

Sponsored Investigation No. FSP 1789

1 Introduction

1.1 Identification of specimen

The sponsor identified the specimen as six (6) retrofit Fire Collars protecting a 150-mm thick concrete floor slab penetrated by three (3) PVC pipes, two (2) HDPE Pipe and one (1) Rehau Raupiano Pipe and floor waste.

1.2 Sponsor

IG6 Pty Ltd as trustee for the IG6 IP Trust
3 Skirmish Court
Victoria Point Qld 4165

1.3 Manufacturer

Snap Fire Systems Pty Ltd
Building A, 1343 Wynnum Road
Tingalpa QLD 4173

1.4 Test standard

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014, Fire-resistance tests of elements of construction.

1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

1.6 Test number

CSIRO Reference test number: FS 4627/4043

1.7 Test date

The fire-resistance test was conducted on 16 November 2016.

2 Description of specimen

2.1 General

The specimen comprised an 1150-mm x 1150-mm x 150-mm thick reinforced concrete slab penetrated by six (6) floor wastes protected by retrofitted Snap Fire Systems fire collars.

The pipes used in the test are stated to be manufactured in accordance with:

- AS/NZS 1260 - PVC-U pipes and fittings for drain, waste and vent application
- AS/NZS 5065:2005 'Polyethylene and polypropylene pipes and fittings for drainage and sewerage applications'
- AS/NZS 7671:2010 'Plastics piping systems for soil and waste discharge (low and high temperature) inside buildings - Polypropylene (PP)(ISO 7671:2003), MOD'

For the purpose of the test, the specimens were referenced as Penetrations 1, 2, 3, 4, 5 and 6. Three (3) specimens are included in this report (Penetration 4, 5 and 6). Documents containing a complete description of each specimen were supplied by the sponsor and are retained on file.

Penetration 4 – LP65R Retrofit fire collar protecting a nominal 65-mm Polyvinyl Chloride (PVC) Pipe incorporating a floor waste and fitting inside the collar

The SNAP Retrofit LP65R fire collar comprised a 0.7-mm steel casing with a 85-mm inner diameter and a 202-mm diameter base flange. The 61-mm high collar casing incorporated a 300-mm x 55-mm x 4-mm thick Intumesh intumescent material. The closing mechanism comprised three stainless steel springs bound with nylon fuse links and a 300-mm x 55-mm stainless steel mesh as shown in drawing numbered LP65R-T dated 13 June 2014, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 30 x 5-mm concrete screws.

The penetrating service comprised a 69-mm PVC pipe and a PVC Coupling, with a total wall thickness of 5.4-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a 65-mm PVC P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a 65-mm PVC End Cap.

The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 4 65-mm PVC Pipe with Fitting Inside Collar– LP65R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Penetration 5 – LP65R Retrofit fire collar protecting a nominal 40-mm High-density polyethylene (HDPE) Pipe incorporating a Floorwaste

The SNAP Retrofit LP65R fire collar comprised a 0.7-mm steel casing with a 85-mm inner diameter and a 202-mm diameter base flange. The 61-mm high collar casing incorporated a 300-mm x 55-mm x 4-mm thick Intumesh intumescent material. The closing mechanism comprised three stainless steel springs bound with nylon fuse links and a 300-mm x 55-mm stainless steel mesh as shown in drawing numbered LP65R-T dated 13 June 2014, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 30 x 5-mm concrete screws.

The penetrating service comprised a 50-mm HDPE pipe, with a wall thickness of 2.5-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a 40-mm HDPE P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a 40-mm HDPE End Cap.

The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 5 40-mm HDPE Pipe – LP65R, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Penetration 6 – LP100R-D Retrofit collar protecting a nominal 80-mm Polyvinyl Chloride (PVC) Pipe incorporating a floorwaste and a fitting inside the collar

The SNAP Retrofit LP100R-D collar comprised a 0.95-mm thick steel casing with a 122-mm inner diameter and a 260-mm base flange. The 65-mm high collar casing incorporated a layer of 418-mm x 59-mm x 5-mm thick Intumescent material. The closing mechanism comprised 4 x 304 stainless steel spring bound with a black nylon fuse link and a 316 stainless steel mesh measuring 415 x 120-mm as shown in drawing numbered LP100R-D-T dated 2 November 2016, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 32-mm Mushroom Head Spikes.

The penetrating service comprised a 82-mm PVC pipe and a 80-mm PVC Coupling, with a total wall thickness of 6-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a PVC P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a PVC End Cap.

The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 6 80-mm PVC Pipe with Fitting Inside Collar– LP100R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

2.2 Dimensions

The overall dimension of the concrete slab was 1150-mm wide x 1150-mm long x 150-mm thick, to suit the opening in the specimen containing frame.

2.3 Orientation

The reinforced concrete slab was placed horizontally on top of the furnace chamber, and subjected to fire exposure from the underside.

2.4 Conditioning

The concrete slab was left to cure for a period longer than 30 days.

3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Drawing numbered LP100R-D-T dated 2 November 2016, by Snap Fire Systems Pty Ltd.

Drawing numbered LP65R-T dated 13 June 2014, by Snap Fire Systems Pty Ltd.

Drawing titled “Test Slab S-16-C Penetration # 4 65-mm PVC Pipe with Fitting Inside Collar– LP65R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Drawing titled “Test Slab S-16-C Penetration # 5 40-mm HDPE Pipe – LP65R, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Drawing titled “Test Slab S-16-C Penetration # 6 80-mm PVC Pipe with Fitting Inside Collar– LP100R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

4 Equipment

4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2014 and was heated by combustion of a mixture of natural gas and air.

4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Location of the thermocouples on the unexposed face of the specimen are described in Appendix A.

4.3 Measurement system

The primary measurement system comprised a multiple-channel data logger, scanning at one minute intervals during the test.

5 Ambient temperature

The temperature of the test area was 23°C at the commencement of the test.

6 Departure from standard

There were no departures from the requirements of AS 1530.4-2014.

7 Termination of test

The test was terminated at 241 minutes by the agreement with the sponsor.

8 Test results

8.1 Critical observations

The following observations were made during the fire-resistance test:

Time	Observation
3 minutes -	Smoke is being emitted from Penetration # 4.
4 minutes -	Cotton Wool pad applied to Penetration # 4 and 6. No ignition.
7 minutes -	Smoke has ceased fluing from Penetration # 4. No smoke is being emitted from Penetration # 5. Light smoke is fluing from Penetration # 6.
30 minutes -	Light smoke is being emitted from Penetration # 6.
45 minutes -	Smoke is being emitted from all specimens with the exception of Penetration # 5.
60 minutes -	No change.
90 minutes -	Light smoke is being emitted from all specimens with the exception of Penetration # 5.
108 minutes -	Smoke is increasing from Penetration # 6.
235 minutes -	Cotton wool pad test applied over Penetration # 6. No ignition.
241 minutes -	Test terminated.

8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.

8.4 Specimen temperature

Figure 3 shows the curve of maximum temperature versus time associated with Penetration 4.

Figure 4 shows the curve of maximum temperature versus time associated with Penetration 5.

Figure 5 shows the curve of maximum temperature versus time associated with Penetration 6.

8.5 Performance

Performance observed in respect of the following AS 1530.4-2014 criteria:

Penetration 4 – LP65R Retrofit fire collar protecting a nominal 65-mm Polyvinyl Chloride (PVC) Pipe incorporating a floor waste and fitting inside the collar

Structural adequacy - not applicable

Integrity - no failure at 241 minutes

Insulation - no failure at 241 minutes

Penetration 5 – LP65R Retrofit fire collar protecting a nominal 40-mm High-density polyethylene (HDPE) Pipe incorporating a Floorwaste

Structural adequacy - not applicable

Integrity - no failure at 241 minutes

Insulation - no failure at 241 minutes

Penetration 6 – LP100R-D Retrofit collar protecting a nominal 80-mm Polyvinyl Chloride (PVC) Pipe incorporating a floorwaste and a fitting inside the collar

Structural adequacy - not applicable

Integrity - no failure at 241 minutes

Insulation - no failure at 241 minutes

This report details methods of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

9 Fire-resistance level (FRL)

For the purpose of building regulations in Australia, the FRL's of the test specimens were as follows:

Penetration 4 -	-/240/240
Penetration 5	-/240/240
Penetration 6 -	-/240/240

For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.11 of AS 1530.4-2014, have been made provided no individual component is removed or reduced.

11 Tested by



Chris Wojcik
Testing Officer

Appendices


Appendix A – Measurement location

Measurement Location		
Group location	T/C Position	T/C designation
Specimen		
Penetration 4 – LP65R Retrofit fire collar protecting a 65-mm Polyvinyl Chloride (PVC) Pipe with fitting inside the collar and Floorwaste	On top of the grate	S10
	On concrete, 25-mm from the opening	S11
	On concrete, 25-mm from the opening	S12
Penetration 5 – LP65R Retrofit fire collar protecting a 40-mm High-density polyethylene (HDPE) Pipe and Floorwaste	On top of the grate	S13
	On concrete, 25-mm from the opening	S14
	On concrete, 25-mm from the opening	S15
Penetration 6 – LP100R-D Retrofit collar protecting a nominal 80-mm Polyvinyl Chloride (PVC) Pipe with fitting inside the collar and Floorwaste	On top of the grate	S16
	On concrete, 25-mm from the opening	S17
	On concrete, 25-mm from the opening	S18


Appendix B – Photographs



PHOTOGRAPH 1 – EXPOSED FACE OF SPECIMENS PRIOR TO TESTING



PHOTOGRAPH 2 – UNEXPOSED FACE OF SPECIMENS PRIOR TO TESTING




PHOTOGRAPH 3 – SPECIMENS AFTER 60 MINUTES OF TESTING



PHOTOGRAPH 4 – SPECIMENS AFTER 120 MINUTES OF TESTING



PHOTOGRAPH 5 – SPECIMENS AFTER 180 MINUTES OF TESTING



PHOTOGRAPH 6 – UNEXPOSED FACED OF SPECIMEN AT CONCLUSION OF TESTING



PHOTOGRAPH 7 – EXPOSED FACE OF SPECIMENS AT CONCLUSION OF TESTING

Appendix C – Furnace Temperature




FIGURE 1 – FURNACE TEMPERATURE




FIGURE 2 – FURNACE SEVERITY




FIGURE 3 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION # 4




FIGURE 4 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION # 5





FIGURE 5 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION # 6


Appendix D – Installation drawings

Test Slab S-16-C Penetration # 4
65mm PVC Pipe w Fitting Inside Collar – LP65R
Date 21 NOV 2016



DRAWING TITLED "TEST SLAB S-16-C PENETRATION # 4 65-MM PVC PIPE WITH FITTING INSIDE COLLAR-LP65R-D, DATED 21 NOVEMBER 2016, BY SNAP FIRE SYSTEMS PTY LTD.


Test Slab S-16-C Penetration # 5
40mm HDPE Pipe – LP65R
Date 21 NOV 2016



11/30/2016 8:10:30 AM


DRAWING TITLED "TEST SLAB S-16-C PENETRATION # 5 40-MM HDPE PIPE – LP65R, DATED 21 NOVEMBER 2016, BY SNAP FIRE SYSTEMS PTY LTD.

Test Slab S-16-C Penetration # 6
 80mm PVC Pipe w Fitting Inside Collar – LP100R-D
 Date 21 NOV 2016




DRAWING TITLED "TEST SLAB S-16-C PENETRATION # 6 80-MM PVC PIPE WITH FITTING INSIDE COLLAR- LP100R-D, DATED 21 NOVEMBER 2016, BY SNAP FIRE SYSTEMS PTY LTD.

Appendix E – Specimen Drawings



DRAWING NUMBERED LP100R-D-T DATED 2 NOVEMBER 2016, BY SNAP FIRE SYSTEMS PTY LTD.



DRAWING NUMBERED LP65R-T DATED 13 JUNE 2014, BY SNAP FIRE SYSTEMS PTY LTD.

Appendix F – Certificates

INFRASTRUCTURE TECHNOLOGIES www.csiro.au		
14 Julius Avenue, North Ryde NSW 2113 PO Box 52, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230		
<h2>Certificate of Test</h2>		No. 2933
<small>“Copyright CSIRO 2016 ©” Copying or alteration of this report without written authorisation from CSIRO is forbidden.</small>		
This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:		
IG6 Pty Ltd as trustee for the IG6 IP Trust 3 Skirmish Court Victoria Point Qld 4165		
A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1789.		
Product Name:	Penetration 4 – LP65R Retrofit fire collar protecting a nominal 65-mm Polyvinyl Chloride (PVC) Pipe incorporating a floor waste and fitting inside the collar	
Description:	The SNAP Retrofit LP65R fire collar comprised a 0.7-mm steel casing with a 85-mm inner diameter and a 202-mm diameter base flange. The 61-mm high collar casing incorporated a 300-mm x 55-mm x 4-mm thick Intumescent intumescent material. The closing mechanism comprised three stainless steel springs bound with nylon fuse links and a 300-mm x 55-mm stainless steel mesh as shown in drawing numbered LP65R-T dated 13 June 2014, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 30 x 5-mm concrete screws. The penetrating service comprised a 69-mm PVC pipe and a PVC Coupling, with a total wall thickness of 5.4-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a 65-mm PVC P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a 65-mm PVC End Cap. The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 4 65-mm PVC Pipe with Fitting Inside Collar– LP65R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.	
Structural Adequacy	not applicable	
Integrity	no failure at 241 minutes	
Insulation	no failure at 241 minutes	
and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/240. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.		
Testing Officer:	Chris Wojcik	Date of Test: 16 November 2016
Issued on the 27 th day of March 2017 without alterations or additions.		
		
Brett Roddy Manager, Fire Testing and Assessments		
	This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025 - Testing	

COPY OF CERTIFICATE OF TEST – NO. 2933



Certificate of Test

No. 2934

"Copyright CSIRO 2016 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
3 Skirmish Court
Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1789.

Product Name: Penetration 5 – LP65R Retrofit fire collar protecting a nominal 40-mm High-density polyethylene (HDPE) Pipe incorporating a Floorwaste

Description: The SNAP Retrofit LP65R fire collar comprised a 0.7-mm steel casing with a 85-mm inner diameter and a 202-mm diameter base flange. The 61-mm high collar casing incorporated a 300-mm x 55-mm x 4-mm thick Intumesh intumescent material. The closing mechanism comprised three stainless steel springs bound with nylon fuse links and a 300-mm x 55-mm stainless steel mesh as shown in drawing numbered LP65R-T dated 13 June 2014, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 30 x 5-mm concrete screws. The penetrating service comprised a 50-mm HDPE pipe, with a wall thickness of 2.5-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a 40-mm HDPE P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a 40-mm HDPE End Cap. The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 5 40-mm HDPE Pipe – LP65R, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Structural Adequacy	not applicable
Integrity	no failure at 241 minutes
Insulation	no failure at 241 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/240. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Chris Wojcik Date of Test: 16 November 2016

Issued on the 27th day of March 2017 without alterations or additions.

Brett Roddy
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing

COPY OF CERTIFICATE OF TEST – NO. 2934



Certificate of Test

No. 2935

"Copyright CSIRO 2016 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
3 Skirmish Court
Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1789.

Product Name: Penetration 6 – LP100R-D Retrofit collar protecting a nominal 80-mm Polyvinyl Chloride (PVC) Pipe incorporating a floorwaste and a fitting inside the collar

Description: The SNAP Retrofit LP100R-D collar comprised a 0.95-mm thick steel casing with a 122-mm inner diameter and a 260-mm base flange. The 65-mm high collar casing incorporated a layer of 418-mm x 59-mm x 5-mm thick Intumescent material. The closing mechanism comprised 4 x 304 stainless steel spring bound with a black nylon fuse link and a 316 stainless steel mesh measuring 415 x 120-mm as shown in drawing numbered LP100R-D-T dated 2 November 2016, by Snap Fire Systems Pty Ltd. One collar was fixed to the underside of the slab using 32-mm Mushroom Head Spikes. The penetrating service comprised a 82-mm PVC pipe and a 80-mm PVC Coupling, with a total wall thickness of 6-mm fitted through the collar's sleeve. The floor waste system was fitted with a chrome brass grate. A 35-mm thick sand/cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a PVC P-Trap was connected to the penetrating pipe, supported by an HKD Anchor and steel clamp to the concrete slab. On the exposed face, the gully trap was capped using a PVC End Cap. The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-16-C Penetration # 6 80-mm PVC Pipe with Fitting Inside Collar- LP100R-D, dated 21 November 2016, by Snap Fire Systems Pty Ltd.

Structural Adequacy	not applicable
Integrity	no failure at 241 minutes
Insulation	no failure at 241 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/240. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Chris Wojcik **Date of Test:** 16 November 2016

Issued on the 27th day of March 2017 without alterations or additions.

Brett Roddy
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing

COPY OF CERTIFICATE OF TEST – NO. 2935

References

The following informative documents are referred to in this Report:

- AS 1530.4-2014 Methods for fire tests on building materials, components and structures Part 4: Fire-resistance tests of elements of building construction.
- AS 4072.1-2005 Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints.

-----end of report-----

CONTACT US

t 1300 363 400
+61 3 9545 2176
e enquiries@csiro.au
w www.csiro.au

YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

FOR FURTHER INFORMATION

Infrastructure Technologies

Brett Roddy
Team Leader, Fire Testing and Assessments
t +61 2 94905449
e brett.rodby@csiro.au
w www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx