

Fire-resistance test on fire collars protecting a CSR Hebel AAC block wall penetrated by services

Test Report

Author: Mario Lara-Ledermann

Report number: FSP 1668

Date: 24 December 2014

Client: Snap Fire Systems Pty Ltd

Commercial-in-confidence



This document is issued in accordance with NATA's accreditation requirements.

Accreditation No. 165 – Corporate Site No. 3625

Accredited for compliance with ISO/IEC 17025


Inquiries should be address to:

Fire Testing and Assessments	Author	The Client
Infrastructure Technologies 14 Julius Avenue North Ryde, NSW 2113 Telephone +61 2 9490 5444	Infrastructure Technologies 14 Julius Avenue North Ryde, NSW 2113 Telephone +61 2 9490 5500	Snap Fire Systems Pty Ltd Unit 2/160 Redland Bay Road Capalaba QLD Telephone +61 7 3245 2133

Report Status and Revision History:

VERSION	STATUS	DATE	DISTRIBUTION	ISSUE NUMBER
Revision A	Final for issue	22/12/2014	CSIRO/SNAP	FSP 1668

Report Authorization:

AUTHOR	REVIEWED BY	AUTHORISED BY
Mario Lara-Ledermann	Brett Roddy	Brett Roddy
		
22 December 2014	22 December 2014	22 December 2014

Use of this Report

Use of Reports – Testing

This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.

Excerpts of the Report may not be published.

Use of Reports – Consultancy

This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.

The Report must not be used as a means of endorsement without the prior written consent of CSIRO.

Copyright and disclaimer

© 2014 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

Contents

1	Introduction	4
1.1	Identification of specimen	4
1.2	Sponsor	4
1.3	Manufacturer	4
1.4	Test standard	4
1.5	Reference standard	4
1.6	Test number	4
1.7	Test date	5
2	Description of specimen	5
2.1	General	5
2.2	Dimensions	6
2.3	Orientation	6
3	Documentation	6
4	Equipment	6
4.1	Furnace	6
4.2	Temperature	6
4.3	Measurement system	7
5	Ambient temperature	7
6	Departure from standard	7
7	Termination of test	7
8	Test results	7
8.1	Critical observations	7
8.2	Furnace temperature	8
8.3	Furnace severity	8
8.4	Specimen temperature	8
8.5	Performance	9
9	Fire-resistance level (FRL)	9
10	Field of direct application of test results	10
11	Tested by	10
	Appendices	11
	Appendix A – Measurement location	11
	Appendix B – Photographs	12
	Appendix C – Furnace Temperature	16
	Appendix D – Installation drawings	20
	Appendix E – Specimen Drawings	22
	Appendix F – Certificates	24
	References	26

Fire-resistance test on fire collars protecting a CSR Hebel AAC block wall penetrated by services

Sponsored Investigation No. FSP 1668

1 Introduction

1.1 Identification of specimen

The sponsor identified the specimen as Snap Retrofitted Fire Collars protecting a CSR Hebel block wall penetrated by one (1) Polyvinyl Chloride (PVC) stack pipe and one (1) High Density Polyethylene (HDPE) stack pipe.

1.2 Sponsor

Snap Fire Systems Pty Ltd
Unit 2/160 Redland Bay Road
CAPALABA QLD

1.3 Manufacturer

Snap Fire Systems Pty Ltd
Unit 2/160 Redland Bay Road
CAPALABA QLD

1.4 Test standard

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005, Fire-resistance tests of elements of construction.

1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

1.6 Test number

CSIRO Reference test number: FS 4459/3795

1.7 Test date

The fire-resistance test was conducted on 11 November 2014.

2 Description of specimen

2.1 General

The specimen comprised a 150-mm thick CSR Hebel block wall, with a stated FRL of -/240/240, penetrated by one (1) Polyvinyl Chloride (PVC) stack pipe and one (1) High Density Polyethylene (HDPE) stack pipe.

For the purpose of the test, the specimens were referenced as Penetrations A and B. Only two specimens are included in this report.

The plastic pipes are stated to be manufactured in accordance with:

- Polyvinyl Chloride (PVC) pipe manufactured in accordance with AS/NSZ 1260.
- High Density Polyethylene (HDPE) pipe manufactured in accordance with ISO 770/8772.

Penetration # A – HP150 R retrofitted fire collar protecting a 160-mm High Density Polyethylene (HDPE) stack pipe

The SNAP retrofitted HP150 R collar comprised a 0.95-mm steel casing with a 175-mm inner diameter and a 326-mm diameter base flange. The 117-mm high collar casing incorporated a strip of 570-mm x 112-mm x 8-mm thick Intumesh intumescent material. The closing mechanism comprised four 304 stainless steel springs, with nylon fuse links, and a 596-mm x 112-mm stainless steel mesh as shown in drawing numbered HP 150 R -T dated 3 November 2014, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 160-mm diameter High Density Polyethylene (HDPE) stack pipe, with a wall thickness of 6.9-mm fitted through a 175-mm diameter hole in the block wall. The pipe projected horizontally 2000-mm away from the unexposed face of the CSR Hebel block wall and 500-mm into the furnace chamber. The pipe was supported at 500-mm and 1000-mm from the unexposed face of the CSR Hebel block wall as shown in drawing titled “Penetration #A – HDPE (160-mm OD) Stack” dated 11 November 2014, by Snap Fire Systems Pty Ltd. On the exposed end, the pipe was capped with a Kaowool Plug.

The annular gap between the pipe and the wall was sealed with a 20-mm deep bead of Fullers Firesound sealant.

Penetration # B – HP250 R retrofitted fire collar protecting a 250-mm diameter Polyvinyl Chloride Sandwich Construction (PVC-SC) stack pipe

The SNAP retrofitted HP250 R collar comprised a 0.95-mm steel casing with a 279-mm inner diameter and a 460-mm diameter base flange. The 184-mm high collar casing incorporated two strips of Intumesh intumescent material, 910-mm x 179-mm x 12-mm thick and 958-mm x 179-mm x 2.5-mm thick. The closing mechanism comprised four stainless steel springs, with nylon fuse links, and a 949-mm x 179-mm 304 stainless steel mesh locate inbetween the intumescent strips as shown in drawing numbered HP 250 R-T dated 14 November 2014, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 250-mm diameter Polyvinyl Chloride Sandwich Construction (PVC-SC) stack pipe, with a wall thickness of 7.25-mm fitted through a 267-mm diameter hole in the block wall. The pipe projected horizontally 2000-mm away from the unexposed face of the CSR Hebel block wall and 500-mm into the furnace chamber. The pipe was supported at 500-mm and 1000-mm from the unexposed face of the CSR Hebel block wall as shown in drawing titled “Penetration #B – PVC-SC (250-mm OD) Stack” dated 11 November 2014, by Snap Fire Systems Pty Ltd. On the exposed end, the pipe was capped with a PVC End cap.

The annular gap between the pipe and the wall was sealed with a 20-mm deep bead of Fullers Firesound sealant.

2.2 Dimensions

The overall dimension of the CSR Hebel block wall was 1150-mm wide x 1150-mm long, to suit the opening in the specimen containing frame.

2.3 Orientation

The CSR Hebel block wall was placed vertically against the furnace chamber.

3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Drawing titled “Penetration #A – HDPE (160-mm OD) Stack” dated 11 November 2014, by Snap Fire Systems Pty Ltd.

Drawing titled “Penetration #B – PVC-SC (250-mm OD) Stack” dated 11 November 2014, by Snap Fire Systems Pty Ltd.

Drawing numbered HP 150 R-T dated 3 November 2014, by Snap Fire Systems Pty Ltd.

Drawing numbered HP 250 R-T dated 14 November 2014, by Snap Fire Systems Pty Ltd.

4 Equipment

4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2005 and was heated by combustion of a mixture of natural gas and air.

4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Location of the thermocouples on the unexposed face of the specimen are described in Appendix A.

4.3 Measurement system

The primary measurement system comprised a multiple-channel data logger, scanning at one minute intervals during the test.

5 Ambient temperature

The temperature of the test area was 19°C at the commencement of the test.

6 Departure from standard

There were no departures from the requirements of AS 1530.4-2005.

7 Termination of test

The test was terminated at 220 minutes by the agreement with the sponsor.

8 Test results

8.1 Critical observations

The following observations were made during the fire-resistance test:

Time	Observation
2 minutes -	Fluing is visible from Penetration #B.
3 minutes -	Dense smoke issues from Penetration #B.
5 minutes -	Fluing is visible from Penetration #A.
6 minutes -	Dense smoke issues from Penetration #A.
7 minutes -	Fluing has decreased from Penetration #B.
16 minutes -	Light smoke is visible from collar of Penetration #B.
21 minutes -	Fluing stops from collar of Penetration #B.
28 minutes -	Fluing is visible from Penetration #B.
36 minutes -	Light smoke is visible from collar of Penetration #A.

37 minutes -	Light smoke fluing from Penetration #B becomes dense.
117 minutes -	Brown-coloured condensate starts issuing forth from Penetration #B.
158 minutes -	Smoke is being emitted from base of Penetration # B. Smoke fluing through Penetration #A. Cotton pad test applied on Penetration #B – no failure.
166 minutes -	Intumescence material is visible at the base of Penetration #B.
178 minutes -	Cotton pad test applied on Penetration #B – no failure.
195 minutes -	<u>Integrity failure on Penetration #B.</u> Cotton pad test applied on the base of the pipe – Ignition noted (photograph 6).
203 minutes -	<u>Insulation failure of penetration # B</u> - maximum temperature rise of 180 deg C is exceeded on the pipe. Pipe of penetration B removed, remaining hole was plugged with ceramic fibre.
215 minutes -	Smoke is being emitted from base of Penetration #A.
217 minutes -	Intumescence material is visible at the base of Penetration A.
219 minutes -	<u>Integrity failure on Penetration #A.</u> Cotton pad test applied on the base of the pipe – Ignition noted (photograph 7).
220 minutes -	<u>Insulation failure of penetration # A</u> – maximum temperature rise of 180 deg C is exceeded on the pipe.
220 minutes -	Test terminated.

8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.

8.4 Specimen temperature

Figure 3 shows the curve of maximum temperature versus time associated with Penetration #A.

Figure 4 shows the curve of maximum temperature versus time associated with Penetration #B.

8.5 Performance

Performance observed in respect of the following AS 1530.4-2005 criteria:

Penetration # A – HP150 R retrofitted fire collar protecting a
160-mm diameter High Density Polyethylene (HDPE) stack pipe

Structural adequacy	-	not applicable
---------------------	---	----------------

Integrity	-	219 minutes
-----------	---	-------------

Insulation	-	220 minutes
------------	---	-------------

Penetration # B – HP250 R retrofitted fire collar protecting a
250-mm diameter Polyvinyl Chloride Sandwich Construction
(PVC-SC) stack pipe

Structural adequacy	-	not applicable
---------------------	---	----------------

Integrity	-	195 minutes
-----------	---	-------------

Insulation	-	203 minutes
------------	---	-------------

This report details methods of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

9 Fire-resistance level (FRL)

For the purpose of building regulations in Australia, the FRL's of the test specimens were as follows:

Penetration #A - -/180/180; and

Penetration #B - -/180/180.

For the purposes of AS 1530.4-2005 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.11 of AS 1530.4-2005, have been made provided no individual component is removed or reduced.

11 Tested by



Mario Lara-Ledermann
Testing Officer

Appendices

Appendix A – Measurement location

Measurement Location		
Group location	T/C Position	T/C designation
Specimen		
Penetration A	On slab 25-mm from collar.	S1
	On slab 25-mm from collar.	S2
	On collar.	S3
	On collar.	S4
	On pipe 25-mm from collar.	S5
	On pipe 25-mm from collar.	S6
Penetration B	On slab 25-mm from collar.	S7
	On slab 25-mm from collar.	S8
	On collar.	S9
	On collar.	S10
	On pipe 25-mm from collar.	S11
	On pipe 25-mm from collar.	S12

Appendix B – Photographs



PHOTOGRAPH 1 – EXPOSED FACE OF SPECIMENS PRIOR TO TESTING



PHOTOGRAPH 2 – UNEXPOSED FACE OF SPECIMENS PRIOR TO TESTING



PHOTOGRAPH 3 – SPECIMENS AFTER 60 MINUTES OF TESTING




PHOTOGRAPH 4 – SPECIMENS AFTER 120 MINUTES OF TESTING



PHOTOGRAPH 5 – SPECIMENS AFTER 180 MINUTES OF TESTING



PHOTOGRAPH 6 – SPECIMEN #B AT 195 MINUTES OF TESTING



PHOTOGRAPH 7 – SPECIMEN #A AT 195 MINUTES OF TESTING



PHOTOGRAPH 8 – SPECIMENS AFTER 220 MINUTES OF TESTING

Appendix C – Furnace Temperature




FIGURE 1 – FURNACE TEMPERATURE




FIGURE 2 – FURNACE SEVERITY




FIGURE 3 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION A






FIGURE 4 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION B

Appendix D – Installation drawings




DRAWING TITLED “PENETRATION #A – HDPE (160-MM OD) STACK” DATED 11 NOVEMBER 2014, BY SNAP FIRE SYSTEMS PTY LTD

Penetration # B
PVC-SC (250 mm Ø) Stack - Date 11-11-2014




**DRAWING TITLED “PENETRATION #B – PVC-SC (250-MM OD) STACK” DATED 11 NOVEMBER 2014, BY
SNAP FIRE SYSTEMS PTY LTD**

Appendix E – Specimen Drawings



DRAWING NUMBERED HP 150R-T DATED 3 NOVEMBER 2014, BY SNAP FIRE SYSTEMS PTY LTD.



DRAWING NUMBERED HP250R-T DATED 14 NOVEMBER 2014, BY SNAP FIRE SYSTEMS PTY LTD.

Appendix F – Certificates

<p>INFRASTRUCTURE TECHNOLOGIES www.csiro.au</p> <p>14 Julius Avenue, North Ryde NSW 2113 PO Box 310, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230</p> 							
<h3>Certificate of Test</h3> <p>No. 2620</p> <p>"Copyright CSIRO 2014 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.</p>							
<p>This is to certify that the element of construction described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005 on behalf of:</p> <p>Snap Fire Systems Pty Ltd Unit 2/160 Redland Bay Road CAPALABA QLD</p>							
<p>A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1668.</p>							
<p>Product Name: Penetration # A – HP150 R retrofitted fire collar protecting a 160-mm High Density Polyethylene (HDPE) stack pipe</p>							
Description:	<p>The SNAP retrofitted HP150 R collar comprised a 0.95-mm steel casing with a 175-mm inner diameter and a 326-mm diameter base flange. The 117-mm high collar casing incorporated a strip of 570-mm x 112-mm x 8-mm thick Intumesh intumescent material. The closing mechanism comprised four 304 stainless steel springs, with nylon fuse links, and a 596-mm x 112-mm stainless steel mesh as shown in drawing numbered HP 150 R -T dated 3 November 2014, by Snap Fire Systems Pty Ltd.</p> <p>The penetrating service comprised a 160-mm diameter High Density Polyethylene (HDPE) stack pipe, with a wall thickness of 6.9-mm fitted through a 175-mm diameter hole in the block wall. The pipe projected horizontally 2000-mm away from the unexposed face of the CSR Hebel block wall and 500-mm into the furnace chamber. The pipe was supported at 500-mm and 1000-mm from the unexposed face of the CSR Hebel block wall as shown in drawing titled "Penetration #A – HDPE (160-mm OD) Stack" dated 11 November 2014, by Snap Fire Systems Pty Ltd. On the exposed end, the pipe was capped with a Ka wool Plug.</p> <p>The annular gap between the pipe and the wall was sealed with a 20-mm deep bead of Fullers Firesound sealant.</p>						
	<table><tr><td>Structural Adequacy</td><td>not applicable</td></tr><tr><td>Integrity</td><td>219 minutes</td></tr><tr><td>Insulation</td><td>220 minutes</td></tr></table>	Structural Adequacy	not applicable	Integrity	219 minutes	Insulation	220 minutes
Structural Adequacy	not applicable						
Integrity	219 minutes						
Insulation	220 minutes						
<p>and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from either direction.</p>							
<p>This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.</p>							
Testing Officer:	Mario Lara-Ledermann						
Date of Test:	11 November 2014						
<p>Issued on the 22nd day of December 2014 without alterations or additions.</p>							
							
<p>Brett Roddy Manager, Fire Testing and Assessments</p>							
	<p>This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025</p>						

COPY OF CERTIFICATE OF TEST – NO. 2620



14 Julius Avenue, North Ryde NSW 2113
PO Box 310, North Ryde NSW 1670, Australia
T (02) 9490 5444 • ABN 41 687 119 230

Certificate of Test

No. 2621

"Copyright CSIRO 2014 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005 on behalf of:

Snap Fire Systems Pty Ltd
Unit 2/160 Redland Bay Road
CAPALABA QLD

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1668.

Product Name: Penetration # B – HP250 R retrofitted fire collar protecting a 250-mm diameter Polyvinyl Chloride Sandwich Construction (PVC-SC) stack pipe

Description: The SNAP retrofitted HP250 R collar comprised a 0.95-mm steel casing with a 279-mm inner diameter and a 460-mm diameter base flange. The 184-mm high collar casing incorporated two strips of Intumesch intumescence material, 910-mm x 179-mm x 12-mm thick and 958-mm x 179-mm x 2.5-mm thick. The closing mechanism comprised four stainless steel springs, with nylon fuse links, and a 949-mm x 179-mm 304 stainless steel mesh located in between the intumescence strips as shown in drawing numbered HP 250 R-T dated 14 November 2014, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 250-mm diameter Polyvinyl Chloride Sandwich Construction (PVC-SC) stack pipe, with a wall thickness of 7.25-mm fitted through a 267-mm diameter hole in the block wall. The pipe projected horizontally 2000-mm away from the unexposed face of the CSR Hebel block wall and 500-mm into the furnace chamber. The pipe was supported at 500-mm and 1000-mm from the unexposed face of the CSR Hebel block wall as shown in drawing titled "Penetration #B – PVC-SC (250-mm OD) Stack" dated 11 November 2014, by Snap Fire Systems Pty Ltd. On the exposed end, the pipe was capped with a PVC End cap.

The annular gap between the pipe and the wall was sealed with a 20-mm deep bead of Fullers Firesound sealant.

Structural Adequacy	not applicable
Integrity	195 minutes
Insulation	203 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from either direction.

This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Mario Lara-Ledermann Date of Test: 11 November 2014

Issued on the 22nd day of December 2014 without alterations or additions.

Brett Roddy
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025

COPY OF CERTIFICATE OF TEST – NO. 2621

References

The following informative documents are referred to in this Report:

- AS 1530.4-2005 Methods for fire tests on building materials, components and structures Part 4: Fire-resistance tests of elements of building construction.
- AS 4072.1-2005 Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints.

CONTACT US

t 1300 363 400
+61 3 9545 2176
e enquiries@csiro.au
w www.csiro.au

YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

FOR FURTHER INFORMATION

Infrastructure Technologies
Mario Lara-Ledermann
Senior Fire Resistance and Assessments Engineer
t +61 2 94905500
e mario.lara@csiro.au
w www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx

Infrastructure Technologies

Brett Roddy
Team Leader, Fire Testing and Assessments
t +61 2 94905449
e brett.roddy@csiro.au
w www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx