

FSP 1146

FIRE-RESISTANCE TEST  
ON FIRE COLLARS RETRO-FITTED  
TO A REINFORCED CONCRETE SLAB

In confidence to  
TRUSS HOLDINGS PTY LTD

19 AUGUST 2005



This Report is confidential and its contents should not be disclosed to any third party. The Report must not be used:

- as a means of advertisement
- in a copying process that is not authorised by CSIRO without the prior written approval of CSIRO

This Report may be made available to other parties for their own use, but only if they agree to be bound by CSIRO's confidentiality requirements.

For more information on CSIRO's confidentiality requirements, please contact CSIRO's Information Management Unit.

FSP 1146

**FIRE-RESISTANCE TEST  
ON FIRE COLLARS RETRO-FITTED  
TO A REINFORCED CONCRETE SLAB**

In confidence to  
**TRUSS HOLDINGS PTY LTD**

19 AUGUST 2005



"Copyright CSIRO 2005 ©"

Copying or alteration of this report without written authorisation from CSIRO is forbidden.

CSIRO – Manufacturing and Infrastructure Technology  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113  
Ph: 02 9490 5444 Fax: 02 9490 5528

This Report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:

- as a means of endorsement; or
- in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.

The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.

Excerpts of the report may not be published.

**MANUFACTURER:** Fire Protection Technology Pty Ltd  
 100/1000 Spring  
 Terranceville QLD

**TEST STANDARDS:** Australian Standard AS/NZS 3533.1:2001 Structural steel tubes  
 components and sections  
 Part 4: Fire resistance test method and performance classification  
 Australian Standard AS/NZS 3533.2:2001 Structural steel tubes  
 components and sections  
 Part 5: Fire resistance test method and performance classification

**TEST NUMBER:** RL 001 001

**TESTED:** Fire Protection Technology Pty Ltd

**AS REPORT:** CSIRO  
 The CSIRO logo is a stylized representation of the sun and stars  
 emblem with the text 'CSIRO' below it.



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

---

**FIRE-RESISTANCE TEST  
ON FIRE COLLARS RETRO-FITTED  
TO A REINFORCED CONCRETE SLAB**

**SPONSORED INVESTIGATION No. FSP 1146**

**IDENTIFICATION  
OF SPECIMEN:**

The sponsor identified the specimens as FireShield Series 2 collars retrofitted to a reinforced concrete slab, protecting floor waste penetrations.

**SPONSOR:**

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

**MANUFACTURER:**

Fire Protection Solutions Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

**TEST STANDARDS:**

Australian Standard 1530, Methods for fire tests on building materials, components and structures,  
Part 4: Fire-resistance tests of elements of building construction -1997;

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements,  
Part 1: Service penetrations and control joints -1992.

**TEST NUMBER:**

FS 3747/2799

**TESTED:**

The fire-resistance test was conducted on 3 May 2005.

**DESCRIPTION  
OF SPECIMEN:**

**GENERAL**

The specimen comprised a 1150-mm x 1150-mm x 150-mm thick reinforced concrete slab penetrated by four HDPE pipes, protected by retro-fitted Fireshield collars.



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**Penetration A – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit PE80 pipe with a  
trap fitting and a plastic floor grate)**

The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height.

The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.

A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve.

The collar was fixed to the underside of the concrete slab using three 5-mm diameter and 40-mm long stainless steel masonry "knock-ins" that passed through the collar's 2-mm thick metal angle brackets. The interface between the steel surface of the collar and the surface of the concrete slab was sealed with a fire resistant sealant. The same sealant was used to seal the gap between the pipe and the cut-out hole on the unexposed side of the concrete slab.

A nominal 50-mm ID HDPE Geberit PE80 pipe, was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting.

**Penetration B – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit Silent pipe with a  
trap fitting and a plastic floor grate)**

The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height.

The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.

A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve.

The collar was fixed to the underside of the concrete slab using three 5-mm diameter and 40-mm long stainless steel masonry "knock-ins" that passed through the collar's 2-mm thick metal angle brackets. The interface between the steel surface of the collar and the surface of the concrete slab was sealed with a fire resistant sealant. The same sealant was used to seal the gap between the pipe and the cut-out hole on the unexposed side of the concrete slab.



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

A nominal 50-mm ID HDPE Geberit Silent pipe, with 3.2-mm wall thickness was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting.

**Penetration C – 65/80/90/100-mm Series 2 Retro-fit FireShield Collar FS2S – 100HFW - Z (100-mm HDPE Silent pipe with a trap fitting and a plastic floor grate)**

The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 140-mm in diameter and 85-mm in height.

The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.

A soft internal insulating wrap lined the internal circumference of the collar. The wrap was 6-mm thick x 85-mm wide, and weighed approximately 300 grams. The wrap was covered on the outside by a 1.5-mm thick x 85-mm wide stainless steel sleeve.

The collar was fixed to the underside of the slab using three 5-mm diameter and 40-mm long steel "anchors" that passed through the collar's 2-mm diameter hole. The interface between the steel surface of the collar and the concrete slab was sealed with a fire resistant sealant. The same sealant was used to seal the gap between the pipe and the cut-out hole on the underside of the concrete slab.

A nominal 100-mm ID HDPE Geberit Silent PE-S2 pipe with 6.0-mm wall thickness, was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 100-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard plastic cap fitting.

**Penetration D – 65/80/90/100-mm Series 2 Retro-fit FireShield Collar FS2S – 100HFW - Z (100-mm HDPE Geberit PE80 pipe with a trap fitting and a plastic floor grate)**

The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 140-mm in diameter and 85-mm in height.

The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.

A soft internal insulating wrap lined the internal circumference of the collar. The wrap was 6-mm thick x 85-mm wide, and weighed approximately 300 grams. The wrap was covered on the outside by a 1.5-mm thick x 85-mm wide stainless steel sleeve.

**Z Type – Research & Development Prototype**  
**NOT For Use or Certification Under Any Circumstances**

**Z Type – Research & Development Prototype**  
**NOT For Use or Certification Under Any Circumstances**



The collar was fixed to the underside of the concrete slab using three 5-mm diameter and 40-mm long stainless steel masonry "knock-ins" that passed through the collar's 2-mm thick metal angle brackets. The interface between the steel surface of the collar and the surface of the concrete slab was sealed with a fire resistant sealant. The same sealant was used to seal the gap between the pipe and the cut-out hole on the unexposed side of the concrete slab.

A nominal 100-mm ID HDPE Geberit PE80 pipe, with 4.3-mm wall thickness, was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 100-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard plastic cap fitting.

#### DIMENSIONS

The specimen's overall dimension was 1150-mm x 1150-mm to suit the opening in the specimen frame.

#### ORIENTATION

The reinforced concrete slab was placed horizontally on top of the furnace chamber.

**DOCUMENTATION:** The following documents were supplied by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Specification, dated 1 June 2005, by Fireball International Pty Ltd

Drawings file Nos. FSTD80, FSTD80A, FSTD80B, FSTD80C and FSTD80D, undated by Fireball Collars Pty Ltd.

Confidential information about the test specimen has been submitted and is retained at the Division of Manufacturing and Infrastructure Technology.

#### EQUIPMENT:

##### FURNACE

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-1997 and was heated by combustion of a mixture of natural gas and air.

##### TEMPERATURE

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.



CSIRO

#### MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

The temperature in the furnace chamber was also measured by two plate thermometer assemblies as specified in ISO 834.1 – 1999.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

#### MEASUREMENT SYSTEM

The primary measurement system comprised a multiple-channel datalogger scanning at one-minute intervals during the test.

#### AMBIENT

**TEMPERATURE:** The temperature of the furnace chamber was 22°C at the commencement of the test.

#### DEPARTURE FROM

**TEST STANDARDS:** There were no departures from the requirements of AS 1530.4-1997 and AS 4072.1-1992.

#### TERMINATION OF TEST:

The test was terminated at 182 minutes by agreement with the sponsor.

#### TEST RESULTS:

##### CRITICAL OBSERVATIONS

The following observations were made during the fire-resistance test:

- 2 minutes - Smoke is fluing from penetration A, its grate is starting to deform.
- 3 minutes - Smoke is fluing from penetration B, its grate is starting to deform.
- 4 minutes - Smoke is fluing from penetration D.
- 5 minutes - Smoke is fluing from penetration C. Grate of penetration D is starting to deform.
- 6 minutes - Insulation Failure of Penetration D – Maximum temperature rise limit of 180 K is exceeded on top of the grate.
- 7 minutes - Insulation Failure of Penetration C – Maximum temperature rise limit of 180 K is exceeded on top of the grate.  
Grate of penetration C is starting to deform.
- 10 minutes - Smoke quantity of all penetrations has decreased.
- 60 minutes - No apparent change to the specimens.
- 110 minutes - Smoke has started to flue from penetrations B & C.
- 145 minutes - Smoke continues to flue from penetrations B & C.
- 182 minutes - Test terminated.

NOT For Use or Certification Under  
Any Circumstances



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**FURNACE TEMPERATURE**

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

**SPECIMEN TEMPERATURE**

Figure 2 shows the curve of maximum temperature versus time associated with Penetration A.

Figure 3 shows the curve of maximum temperature versus time associated with Penetration B.

Figure 4 shows the curve of maximum temperature versus time associated with Penetration C.

Figure 5 shows the curve of maximum temperature versus time associated with Penetration D.

**PERFORMANCE**

Performance observed in respect of the following heating conditions and general AS 1530.4-1997 criteria:

Penetration A – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit PE80 pipe with a trap fitting and a plastic floor grate)

Structural adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

Penetration B – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit Silent pipe with a trap fitting and a plastic floor grate)

Structural adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

Penetration C – 65/80/90/100-mm Series 2 Retro-fit FireShield Collar  
FS2S – 100HFW - Z (100-mm HDPE Silent pipe with a trap fitting and a plastic floor grate)

Structural adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

**Z Type – Research & Development Prototype**  
**NOT For Use or Certification Under Any Circumstances**



Penetration D – 65/80/90/100-mm Series 2 Retro-fit FireShield Collar  
FS2S – 100HFW - Z (100-mm HDPE Geberit PE80 pipe with  
a tran fitting and a plastic floor grate)

Structural adequacy Z Type – Research & Development  
Integrity Prototype

Insulation **NOT For Use or Certification Under Any  
Circumstances**

For the purposes of AS 1530.4 – 1997, the results only relate to the behaviour of  
the element of construction under the particular conditions of test; they are not  
intended to be the sole criteria for assessing the potential fire performance of  
the element in use, nor do they reflect the actual behaviour in fires.

**FIRE-RESISTANCE  
LEVEL:**

For the purpose of building regulations in Australia, the fire-resistance levels  
(FRL) of the test specimens are as follows:

Penetration A	-/180/180
Penetration B	-/180/180
Penetration C	-/180/0
Penetration D	-/180/0

The fire-resistance level is applicable for exposure to fire from the same side as  
tested.

**APPENDICES:**

**APPENDIX 1**

Page 23

Page 24

Photograph 1 - Specimens (exposed side) prior to testing.....	Page 10
Photograph 2 - Specimens (unexposed side) prior to testing.....	Page 10
Photograph 3 - Specimens at 61 minutes into the test.....	Page 11
Photograph 4 - Specimens at 121 minutes into the test.....	Page 11
Photograph 5 - Specimens at 181 minutes into the test.....	Page 12
Photograph 6 - Specimens (exposed side) after the completion of testing.....	Page 12



APPENDIX 2

Figure 1. - FURNACE TEMPERATURE..... Page 13

Figure 2. - SPECIMEN TEMPERATURE-  
Maximum temperature associated with penetration A..... Page 14

Figure 3. - SPECIMEN TEMPERATURE-  
Maximum temperature associated with penetration B..... Page 15

Figure 4. - SPECIMEN TEMPERATURE-  
Maximum temperature associated with penetration C. .... Page 16

Figure 5. - SPECIMEN TEMPERATURE-  
Maximum temperature associated with penetration D. .... Page 17

APPENDIX 3

Drawing file No. FSTD80, undated, by Fireball Collars Pty Ltd ..... Page 18

Drawing file No. FSTD80A, undated, by Fireball Collars Pty Ltd..... Page 19

Drawing file No. FSTD80B, undated, by Fireball Collars Pty Ltd..... Page 20

Drawing file No. FSTD80C, undated, by Fireball Collars Pty Ltd..... Page 21

Drawing file No. FSTD80D, undated, by Fireball Collars Pty Ltd..... Page 22

APPENDIX 4

A copy of Certificate of Test No. 1925..... Page 23


A copy of Certificate of Test No. 1926..... Page 24

A copy of Certificate of Test No. 1927..... Page 25

A copy of Certificate of Test No. 1928..... Page 26

TESTED BY:

  
Chris Wojcik  
Testing Officer

  
Garry Collins  
Manager, Fire Testing and Assessment

19 AUGUST 2005



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



Photograph 1 - Specimens (exposed side) prior to testing.



Photograph 2 - Specimens (unexposed side) prior to testing.



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



Photograph 3 – Specimens at 61 minutes into the test.



Photograph 4 – Specimens at 121 minutes into the test.




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY


"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



Photograph 5 – Specimens at 181 minutes into the test.



Photograph 6 – Specimens (exposed side) after the completion of testing.



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.




Fig. 1 – FURNACE TEMPERATURE




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**Fig. 2 – SPECIMEN TEMPERATURE**  
Maximum temperature associated with Penetration A.




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©". Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.





**Fig. 3 – SPECIMEN TEMPERATURE**  
Maximum temperature associated with Penetration B.




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 @" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**Fig. 4 – SPECIMEN TEMPERATURE**  
Maximum temperature associated with Penetration C.




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

\*Copyright CSIRO 2005 © Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**Fig. 5 – SPECIMEN TEMPERATURE**  
Maximum temperature associated with Penetration D.





MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**FireShield Series 2 collars with floor wastes retrofit to concrete slab**



Drawing No.	FSTD80120505
File	FSTD80
Part No.	FS2550H FS25100H
Pat. Pending	2003900592
Copyright by Fireball International Pty Ltd. All rights reserved. No part of this work covered by the copyright hereon may be reproduced or used in any form or by any means - graphic, electronic or mechanical, including photography, recording, taping, or information storage and retrieval systems - without written permission of the publisher.	
All dimensions in mm.	




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.




This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**Detail drawing A**  
**50 mm HDPE pipe with floor waste in**  
**FireShield Series 2 50 mm retrofit to slab**



- A** Rondo furring channels
- B** Angled metal bracket (2 mm thick)
- C** End cap
- D** FireShield retrofit collar (1 mm thick metal)
- E** FireShield cast-in collar (Polypropylene)
- F** Floor flange
- G** Intumescent and glass sleeve
- H** FireShield cast-in collar (metal)
- I** Intumescent
- J** Intumescent and stainless steel sleeve
- K** 3 sheets of 16 mm Fyrchek® plasterboard
- L** Fusible link
- M** Cement mortar
- N** Spring for closing fire collar
- O** Ceiling frame at 600 mm centres
- P** Metal plate (1 mm thick)
- R** Floor grate
- S** Fire-rated sealant
- T** Steel angles fixed to surface of sheeting
- U** Stainless steel knock-in (5 x 40 mm long)
- V** Screw into wall frame (5 x 40 mm long)
- W** Screw into steel angles or Rondo furring channels (5 x 20 mm long)
- X** Fibreglass liner
- Z** 50 mm HDPE pipe



Drawing No.	<b>FSTD80A</b>
File	<b>FSTD80A</b>
Part No.	<b>FS2S50H</b>
Pat. Pending	<b>2003900592</b>
<small>Copyright by Fireball International Pty Ltd. All rights reserved. No part of this work covered by the copyright herein may be reproduced or used in any form or by any means - graphic, electronic or mechanical, including photography, recording, taping, or information storage and retrieval systems - without written permission of the publisher.</small>	
All dimensions in mm.	




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.




This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**Detail drawing B**  
**50 mm Silent thickwall HDPE pipe with floor waste**  
**in FireShield Series 2 50 mm retrofit to slab**



- A** Rondo furring channels
- B** Angled metal bracket (2 mm thick)
- C** End cap
- D** FireShield retrofit collar (1 mm thick metal)
- E** FireShield cast-in collar (Polypropylene)
- F** Floor flange
- G** Intumescent and glass sleeve
- H** FireShield cast-in collar (metal)
- I** Intumescent
- J** Intumescent and stainless steel sleeve
- K** 3 sheets of 16 mm Fyrchek® plasterboard
- L** Fusible link
- M** Cement mortar
- N** Spring for closing fire collar
- O** Ceiling frame at 600 mm centres
- P** Metal plate (1 mm thick)
- R** Floor grate
- S** Fire-rated sealant
- T** Steel angles fixed to surface of sheeting
- U** Stainless steel knock-in (5 x 40 mm long)
- V** Screw into wall frame (5 x 40 mm long)
- W** Screw into steel angles or Rondo furring channels (5 x 20 mm long)
- X** Fibreglass liner
- Z** 50 mm Silent thickwall HDPE pipe



Drawing No.	FSTD80B120505
File	FSTD80B
Part No.	FS2550H
Pat. Pending	2003900592
<small>Copyright by Fireball International Pty Ltd. All rights reserved. No part of this work covered by the copyright herein may be reproduced or used in any form or by any means - graphic, electronic or mechanical, including photography, recording, taping, or information storage and retrieval systems - without written permission of the publisher.</small>	
All dimensions in mm.	




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.




This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**Detail drawing C**  
**100 mm Silent thickwall HDPE pipe with floor waste in**  
**FireShield Series 2 100 mm retrofit to slab**



- A Rondo furring channels
- B Angled metal bracket (2 mm thick)
- C End cap
- D FireShield retrofit collar (1 mm thick metal)
- E FireShield cast-in collar (Polypropylene)
- F Floor flange
- G Intumescent and glass sleeve
- H FireShield cast-in collar (metal)
- I Intumescent
- J Intumescent and stainless steel sleeve
- K 3 sheets of 16 mm Fyrchek® plasterboard
- L Fusible link
- M Cement mortar
- N Spring for closing fire collar
- O Ceiling frame at 600 mm centres
- P Metal plate (1 mm thick)
- R Floor grate
- S Fire-rated sealant
- T Steel angles fixed to surface of slab
- U Stainless steel knock-out
- V Screw into wall frame
- W Screw into steel furring channels (5 x 10 mm)
- X Fibreglass plaster
- Z 100 mm Silent thickwall HDPE pipe



Drawn	No. FSP1146
File	1146
Proj. No.	FSP1146
Heading	1146
<small>Copyright in this drawing is owned by CSIRO. All rights reserved. No part of this drawing may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without written permission from CSIRO.</small>	
All dimensions in mm.	




MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

**Detail drawing D**  
**100 mm HDPE pipe with floor waste**  
**in FireShield Series 2 100 mm retrofit to slab**



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



# Certificate of Test

No. 1925

"Copyright CSIRO 2005 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration A – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit PE80 pipe with a trap fitting and a plastic floor grate)

Description: The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height. The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius. A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve. A nominal 50-mm ID HDPE Geberit PE80 pipe, was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting. Construction is detailed in drawing file No. FSTD80A, undated, by Fireball Collars Pty Ltd.

The element of construction described above satisfied the following criteria for fire-resistance for the period stated.

Structural Adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.

*Garry E Collins*

Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

# Certificate of Test

No. 1926

"Copyright CSIRO 2005 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration B – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit Silent pipe with a trap fitting and a plastic floor grate)

Description: The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height. The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius. A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve. A nominal 50-mm ID HDPE Geberit Silent pipe, with 3.2-mm wall thickness was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting. Construction is detailed in drawing file No. FSTD80B, undated, by Fireball Collars Pty Ltd.

The element of construction described above satisfied the following criteria for fire-resistance for the period stated.

Structural Adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.

*Garry E Collins*

Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

# Certificate of Test

No. 1927

Copyright CSIRO 2005 ©

Copying or alteration of this report without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration C - 65/80/90/100-mm Series 2 Retro-fit FireShield Collar  
FS2S - 100HFW - Z (100-mm HDPE Silent pipe with a trap fitting and elastic floor grate)

Description: The Series 2 FireShield Collar consisted of a 1.2-mm thick steel case, 140-mm in diameter and 140-mm in height. The collar incorporated 14 springs which were pivoted at the top of the spring metal casings and restrained by a nylon tape. The testing temperature of 75 degrees Celsius. A 100-mm diameter wrap level was used in the circumference of the collar. The wrap was 6-mm thick x 850-mm long and weighed approximately 100 grams. The wrap was covered on the outside by a 0.35mm thick polyethylene film. The pipe, which had a 6.0-mm wall thickness, was fitted through the collar and the pipe was positioned approximately flush with the top of the concrete slab. On the inside of the collar, a 100-mm diameter trap fitting with water was inserted into the collar. On the outside, a 100-mm diameter elastic floor grate was fitted. The pipe was capped on the top. On the exposed side of the slab, the pipe was capped with a 100-mm diameter elastic floor grate. Construction is detailed in the report FSP 1146, issued by Truss Holdings Pty Ltd.

**NOT For Use or Certification Under Any Circumstances**  
**Z Type - Research & Development Prototype**

The element of construction described above was tested in accordance with the criteria for fire-resistance for the period stated.

- Structural Adequacy -
- Integrity -
- Insulation -

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/0. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.

*Garry E Collins*

Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555



MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

# Certificate of Test

No. 1928

Copyright CSIRO 2005 ©  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration D - 100/90/100-mm Series 2 Retro-fit FireShield Collar  
- 100HFW - Z (100-mm HDPE Geberit PE80 pipe with a trap  
and a plastic floor grate)

Description: The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 140-mm in diameter and 85-mm in height. It was pivoted at the top of the spring metal casings and supported 3 apertures. The maximum temperature of 75 degrees Celsius. A multi-layered wrap covered the interior surface of the collar. The wrap was 6-mm thick x 85-mm wide and approximately 1.2m long. The wrap was covered on the outside by a 0.35-mm thick x 85-mm wide x 1.2m long polyethylene film. The film thickness, was fitted through the collar. The polyethylene film was inserted into the collar. On the exposed side of the collar, the apertures were capped at the top with a standard 100-mm diameter trap. On the exposed side of the slab, the pipe was capped with a standard 100-mm diameter trap. Construction is detailed in FSP 1146.

The element of construction described above satisfied the requirements for fire-resistance for the period stated.

Structural Adequacy	-	not assessed
Integrity	-	no failure at 152 minutes
Insulation	-	6 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/0. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.

*Garry E Collins*  
Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555



## MANUFACTURING & INFRASTRUCTURE TECHNOLOGY

"Copyright CSIRO 2005 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.

# Certificate of Test

No. 1925

"Copyright CSIRO 2005 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration A – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit PE80 pipe with a trap fitting and a plastic floor grate)

Description: The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height.  
The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.  
A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve.  
A nominal 50-mm ID HDPE Geberit PE80 pipe, was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting.  
Construction is detailed in drawing file No. FSTD80A, undated, by Fireball Collars Pty Ltd.

The element of construction described above satisfied the following criteria for fire-resistance for the period stated.

Structural Adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.

Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**  
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555

# Certificate of Test

No. 1926

"Copyright CSIRO 2005 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-1997 and Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints -1992, on behalf of

Truss Holdings Pty Ltd  
161 Railway Parade  
THORNSIDE QLD

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FSP 1146.

Product Name: Penetration B – 40/50-mm Series 2 Retro-fit FireShield Collar  
FS2S – 50HFW (50-mm HDPE Geberit Silent pipe with a trap fitting and a plastic floor grate)


Description: The Series 2 Retro-fit FireShield Collar consisted of a 1.2-mm thick steel case, 85-mm in diameter and 60-mm in height.  
The collar incorporated 3 springs, these were pivoted at the top of the spring metal casings and restrained by a nylon fusible link with a melting temperature of 75 degrees Celsius.  
A soft intumescent wrap lined the internal circumference of the collar. The wrap was 4-mm thick x 57-mm wide, and weighed approximately 75 grams. The wrap was covered on the outside by a 0.35-mm thick x 57-mm wide stainless steel sleeve.  
A nominal 50-mm ID HDPE Geberit Silent pipe, with 3.2-mm wall thickness was fitted through the collar's sleeve. The pipe projected vertically, approximately flush with the top of the concrete slab. On the exposed side of the slab, a HDPE trap fitting filled with water was inserted into the collar that projected approximately 150-mm into the furnace chamber. The pipe was capped at the top with a standard 50-mm diameter plastic floor grate. On the exposed side of the slab, the pipe was capped with a standard HDPE cap fitting.  
Construction is detailed in drawing file No. FSTD80B, undated, by Fireball Collars Pty Ltd.

The element of construction described above satisfied the following criteria for fire-resistance for the period stated.

Structural Adequacy	-	not applicable
Integrity	-	no failure at 182 minutes
Insulation	-	no failure at 182 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to fire from the same side as tested.

Testing Officer: Chris Wojcik Date of Test: 3 May 2005  
Issued on the 19<sup>th</sup> day of August 2005 without alterations or additions.



Garry E Collins  
Manager, Fire Testing and Assessments



This laboratory is accredited (Accreditation No. 3632) by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of accreditation.



**CSIRO Manufacturing & Infrastructure Technology**

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA  
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555