

Fire-resistance test on fire collars protecting a concrete floor slab penetrated by services

Test Report

Author: Peter Gordon
Report number: FSP 2016
Date: 19 August 2019

Client: IG6 Pty Ltd as trustee for the IG6 IP Trust

Commercial-in-confidence

Inquiries should be address to:

Fire Testing and Assessments	Author	The Client
NATA Registered Laboratory	Infrastructure Technologies	IG6 Pty Ltd as trustee for the IG6 IP Trust
14 Julius Avenue	14 Julius Avenue	3 Skirmish Court
North Ryde, NSW 2113	North Ryde, NSW 2113	Victoria Point Qld 4165
Telephone +61 2 9490 5444	Telephone +61 2 9490 5500	

Report Status and Revision History:

VERSION	STATUS	DATE	DISTRIBUTION	ISSUE NUMBER
Revision A	Draft for review	26/06/2019	CSIRO and The Client	FSP 2016
Revision B	Final for issue	19/08/2019	CSIRO and The Client	FSP 2016

Report Authorisation:

AUTHOR	REVIEWED BY	AUTHORISED BY
Peter Gordon	Glenn Williams	Brett Roddy



19 August 2019

19 August 2019

19 August 2019

Use of this Report

Use of Reports – Testing

This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.

Excerpts of the Report may not be published.

Use of Reports – Consultancy

This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.

The Report must not be used as a means of endorsement without the prior written consent of CSIRO.

Copyright and disclaimer

© 2019 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

Contents

1	Introduction	5
1.1	Identification of specimen	5
1.2	Sponsor	5
1.3	Manufacturer	5
1.4	Test standard	5
1.5	Reference standard.....	5
1.6	Test number.....	6
1.7	Test date	6
2	Description of specimen	6
2.1	General.....	6
2.2	Dimensions	8
2.3	Orientation.....	8
2.4	Conditioning.....	8
2.5	Selection, construction and installation of the specimen and the supporting construction	8
3	Documentation	9
4	Equipment.....	9
4.1	Furnace	9
4.2	Temperature	9
4.3	Measurement system	10
5	Ambient temperature	10
6	Departure from standard	10
7	Termination of test	10
8	Test results	10
8.1	Critical observations	10
8.2	Furnace temperature.....	11
8.3	Furnace severity.....	11
8.4	Specimen temperature.....	11
8.5	Performance	12
9	Fire-resistance level (FRL)	13
10	Field of direct application of test results	13
11	Tested by.....	13
Appendices		14
Appendix A – Measurement location		14
Appendix B – Photographs.....		15
Appendix C – Test Data Sheets.....		21
Appendix D – Installation drawings.....		28
Appendix E – Specimen Drawings		34
Appendix F – Certificate(s) of Test		37
References.....		42

Fire-resistance test on fire collars protecting a concrete floor slab penetrated by services

Sponsored Investigation No. FSP 2016

1 Introduction

1.1 Identification of specimen

The sponsor identified the specimen as five (5) cast-in fire collars protecting a 120-mm thick concrete floor slab penetrated by five (5) stack pipes.

1.2 Sponsor

IG6 Pty Ltd as trustee for the IG6 IP Trust
3 Skirmish Court
Victoria Point Qld 4165

1.3 Manufacturer

Snap Fire Systems Pty Ltd
Building A, 1343 Wynnum Road
Tingalpa QLD 4173

1.4 Test standard

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014, Fire-resistance tests of elements of construction.

Section 10: Service penetrations and control joints

1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

1.6 Test number

CSIRO Reference test number: FS 4888/4398

1.7 Test date

The fire-resistance test was conducted on 26 June 2019.

2 Description of specimen

2.1 General

The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by five (5) stack pipes protected by five Snap Fire Systems Cast-in Snap Fire Systems fire collars.

The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures.

The pipes used in the test are stated to be manufactured in accordance with:

- AS/NZS 1260 'PVC-U pipes and fittings for drain, waste and vent application'; and
- AS/NZS 7671:2010 Plastics piping systems for soil and waste discharge (low and high temperature) inside buildings— Polypropylene (PP).

For the purpose of the test, the five penetrations were referenced as Specimens 1, 2, 3, 4, and 5. Documents containing a complete description of each specimen were supplied by the sponsor and are retained on file.

Specimen 1 – SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polyvinyl chloride (PVC-U) stack pipe.

The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67-mm inner diameter and a 150-mm diameter base flange. The 250-mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S-RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 55.85-mm outside diameter polyvinyl chloride pipe with a wall thickness of 2.23-mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #1, 50 PVC Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap on the exposed end.

Specimen 2 – SNAP H65S-RR Cast-in collar protecting a nominal 65-mm polyvinyl chloride (PVC-U) stack pipe.

The SNAP Cast-in H65S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 79-mm inner diameter and a 168-mm diameter base flange. The 250-mm high collar casing incorporated a 280-mm x 65-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 322-mm x 65-mm 304 stainless steel mesh as shown in drawing numbered H65S-RR dated 29 September 2017, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 68.68-mm outside diameter polyvinyl chloride pipe with a wall thickness of 2.85-mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #2, 65 PVC Stack & H65S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap on the exposed end.

Specimen 3 – SNAP H100S-RR Cast-in collar protecting a nominal 110-mm polyvinyl chloride sandwich construction (PVC-SC) stack pipe.

The SNAP Cast-in H100S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 126.5-mm inner diameter and a 213-mm diameter base flange. The 250-mm high collar casing incorporated a 412-mm x 85-mm x 4-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three equally spaced 3.15-mm diameter galvanised steel springs bound with nylon fuse links acting against a 460-mm x 83-mm 316 stainless steel mesh as shown in drawing numbered H100S-RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 110-mm outside diameter polyvinyl chloride sandwich construction pipe with a wall thickness of 3.4-mm fitted through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #3, 110 Triplus Stack & H100S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap.

Specimen 4 – SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polypropylene (Valsir Triplus) stack pipe.

The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67-mm inner diameter and a 150-mm diameter base flange. The 250-mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S-RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 49.6-mm outside diameter polypropylene pipe with a wall thickness of 2.29-mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #4, 50 Triplus Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a Superwool plug on the exposed end.

Specimen 5 – SNAP H50S-RR Cast-in collar protecting a nominal 40-mm polypropylene (Valsir Triplus) stack pipe.

The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67-mm inner diameter and a 150-mm diameter base flange. The 250-mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S-RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 40-mm outside diameter polypropylene pipe with a wall thickness of 2.32-mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #5, 40 Triplus Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a Superwool plug on the exposed end.

2.2 Dimensions

The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab to suit the opening in the specimen containing frame.

2.3 Orientation

The reinforced concrete slab was placed horizontally on top of the furnace chamber, and subjected to fire exposure from the underside.

2.4 Conditioning

The concrete slab was left to cure for a period longer than 30 days.

2.5 Selection, construction and installation of the specimen and the supporting construction

The supporting wall construction and specimen installation was organised by the sponsor. CSIRO was not involved in the selection of the materials.

3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Drawing titled “Test Slab S-19-D Layout”, dated 8 May 2019 provided by Snap Fire Systems Pty Ltd.

Drawing titled “Specimen #1, 50 PVC Stack & H50S-RR”, dated 15 May 2019, provided by Snap Fire Systems Pty Ltd.

Drawing titled “Specimen #2, 65 PVC Stack & H65S-RR”, dated 15 May 2019, provided by Snap Fire Systems Pty Ltd.

Drawing titled “Specimen #3, 110 Triplus Stack & H100S-RR”, dated 15 May 2019, provided by Snap Fire Systems Pty Ltd.

Drawing titled “Specimen #4, 50 Triplus Stack & H50S-RR”, dated 15 May 2019, provided by Snap Fire Systems Pty Ltd.

Drawing titled “Specimen #5, 40 Triplus Stack & H50S-RR”, dated 15 May 2019, provided by Snap Fire Systems Pty Ltd.

Drawing number H100S-RR-T, dated 29 September 2017, by Snap Fire Systems Pty Ltd.

Drawing number H65S-RR dated 29 September 2017, by Snap Fire Systems Pty Ltd.

Drawing number H50S-RR-T, dated 29 September 2017, by Snap Fire Systems Pty Ltd.

4 Equipment

4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2014 and was heated by combustion of a mixture of natural gas and air.

4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Location of the thermocouples on the unexposed face of the specimen are described in Appendix A.

4.3 Measurement system

The primary measurement system comprised a multiple-channel data logger, scanning at one minute intervals during the test.

5 Ambient temperature

The temperature of the test area was 15°C at the commencement of the test.

6 Departure from standard

There were no departures from the requirements of AS 1530.4-2014.

7 Termination of test

The test was terminated at 241 minutes by the agreement with the sponsor.

8 Test results

8.1 Critical observations

The following observations were made during the fire-resistance test:

Time	Observation
2 minutes -	Smoke is fluing from the end of the pipes of Specimens 1 ,2 and 4.
3 minutes -	Smoke is fluing from the end of the pipe of Specimen 3. Smoke is fluing from the end of the pipe of Specimen 2 and 4.
4 minutes -	Smoke continue to flue from Specimens 1 and 3.
5 minutes -	The level of smoke fluing from Specimen 1 has reduced. All other specimens have ceased fluing.
8 minutes -	Smoke level fluing from Specimen 1 has reduced.
12 minutes -	Smoke is being emitted from the base of Specimen 1 and continues to flue from the end of pipe.
20 minutes -	Moisture is present on the concrete at the base of Specimens 1, 3 and 4. A small quantity of smoke is fluing from the end of pipe of Specimen 3
35 minutes -	Smoke continues to flue from Specimen 3.
43 minutes -	Intumescent sealant around the base of Specimen 5 has begun to swell.
61 minutes -	Steam is being emitted from the concrete slab and water is pooling at the base of Specimen 3.
98 minutes -	Steam is continuing to be emitted from the concrete slab.

- 120 minutes - Intumescent sealant around the base of Specimens 2, 3, 4 and 5 has swollen.
- 148 minutes - Insulation failure of Specimen 3 - maximum temperature rise of 180K is exceeded on the slab 25-mm from mastic on the unexposed face.
- 177 minutes - Insulation failure of Specimen 1 - maximum temperature rise of 180K is exceeded on the slab 25-mm from mastic on the unexposed face.
- 179 minutes - Insulation failure of Specimen 4 - maximum temperature rise of 180K is exceeded on the slab 25-mm from mastic on the unexposed face.
- 181 minutes - A small amount of smoke is fluing from the pipe of Specimen 2.
- 184 minutes - Insulation failure of Specimen 2 - maximum temperature rise of 180K is exceeded on the slab 25-mm from mastic on the unexposed face.
- 196 minutes - Insulation failure of Specimen 5 - maximum temperature rise of 180K is exceeded on the slab 25-mm from screed on the unexposed face.
- 232 minutes - Smoke is being emitted from the base of Specimen 5. Specimen 3 has resumed fluing smoke from pipe.
- 241 minutes - Test terminated

8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.

8.4 Specimen temperature

Figure 3 shows the curve of temperature versus time associated with Specimen 1.

Figure 4 shows the curve of temperature versus time associated with Specimen 2.

Figure 5 shows the curve of temperature versus time associated with Specimen 3.

Figure 6 shows the curve of temperature versus time associated with Specimen 4.

Figure 7 shows the curve of temperature versus time associated with Specimen 5.

8.5 Performance

Performance observed in respect of the following AS 1530.4-2014 criteria:

Specimen 1 – SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polyvinyl chloride (PVC-U) stack pipe.

Structural adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	177 minutes

Specimen 2 – SNAP H65S-RR Cast-in collar protecting a nominal 65-mm polyvinyl chloride (PVC-U) stack pipe.

Structural adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	184 minutes

Specimen 3 – SNAP H100S-RR Cast-in collar protecting a nominal 110-mm polyvinyl chloride sandwich construction (PVC-SC) stack pipe.

Structural adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	148 minutes

Specimen 4 – SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polypropylene (Valsir Triplus) stack pipe.

Structural adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	179 minutes

Specimen 5 – SNAP H50S-RR Cast-in collar protecting a nominal 40-mm polypropylene (Valsir Triplus) stack pipe.

Structural adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	196 minutes

This report details methods of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

9 Fire-resistance level (FRL)

For the purpose of building regulations in Australia, the FRL's of the test specimens were as follows:

Specimen 1	-	-/240/120
Specimen 2	-	-/240/120
Specimen 3	-	-/240/120
Specimen 4	-	-/240/120
Specimen 5	-	-/240/120

The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested.

For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.11 of AS 1530.4-2014, have been made provided no individual component is removed or reduced.

11 Tested by



Peter Gordon
Testing Officer

Appendices

Appendix A – Measurement location

Specimen	T/C Position	T/C designation
SPECIMEN 1 - Iplex PVC 55.85-mm OD x 2.23-mm wall thickness stack pipe protected with a H50S-RR Cast-in fire collar.	On top of the slab – 25-mm from Mastic North	S1
	On top of the slab – 25-mm from Mastic South/East	S2
	On Pipe 25-mm above mastic East	S3
	On Pipe 25-mm above mastic South	S4
SPECIMEN 2 – Iplex PVC 68.68-mm OD x 2.85-mm wall thickness stack pipe protected with a H65S-RR Cast-in fire collar.	On top of the slab – 25-mm from Mastic North	S5
	On top of the slab – 25-mm from Mastic South	S6
	On Pipe 25-mm above mastic West	S7
	On Pipe 25-mm above mastic South	S8
SPECIMEN 3 – Iplex PVC-SC 110.52-mm OD x 3.47-mm wall thickness stack pipe protected with a H100S-RR Cast-in fire collar.	On top of the slab – 25-mm from Mastic North /East	S9
	On top of the slab – 25-mm from Mastic West	S10
	On Pipe 25-mm above mastic North	S11
	On Pipe 25-mm above mastic South	S12
SPECIMEN 4 – Valsir Triplus polypropylene 49.6-mm OD x 2.29-mm wall thickness stack pipe protected with a H50S-RR Cast-in fire collar.	On top of the slab – 25-mm from Mastic North	S13
	On top of the slab – 25-mm from Mastic South/East	S14
	On Pipe 25-mm above mastic East	S15
	On Pipe 25-mm above mastic North	S16
SPECIMEN 5 – Valsir Triplus polypropylene 49.6-mm OD x 2.29-mm wall thickness stack pipe protected with a H50S-RR Cast-in fire collar.	On top of the slab – 25-mm from Mastic South/East	S17
	On top of the slab – 25-mm from Mastic South/West	S18
	On Pipe 25-mm above mastic South/West	S19
	On Pipe 25-mm above mastic North/East	S20
Rover	Rover	S21
Ambient	Ambient	S22

Appendix B – Photographs



PHOTOGRAPH 1 – EXPOSED FACE OF SPECIMENS PRIOR TO TESTING




PHOTOGRAPH 2 – UNEXPOSED FACE OF SPECIMENS PRIOR TO TESTING



PHOTOGRAPH 3 – SPECIMENS AFTER 35 MINUTES OF TESTING




PHOTOGRAPH 4 – SPECIMENS AFTER 60 MINUTES OF TESTING




PHOTOGRAPH 5 – SPECIMENS AFTER 90 MINUTES OF TESTING



PHOTOGRAPH 6 – SPECIMENS AFTER 120 MINUTES OF TESTING



PHOTOGRAPH 7 – SPECIMENS AFTER 150 MINUTES OF TESTING



PHOTOGRAPH 8 – SPECIMENS AFTER 180 MINUTES OF TESTING



PHOTOGRAPH 9 – SPECIMENS AFTER 210 MINUTES OF TESTING



PHOTOGRAPH 10 – SPECIMENS AFTER 240 MINUTES OF TESTING



PHOTOGRAPH 11 – UNEXPOSED FACED OF SPECIMENS AT THE CONCLUSION OF TESTING



PHOTOGRAPH 12 – EXPOSED FACE OF SPECIMENS AFTER THE CONCLUSION OF TESTING

Appendix C – Test Data Sheets




FIGURE 1 – FURNACE TEMPERATURE




FIGURE 2 – FURNACE SEVERITY




FIGURE 3 – SPECIMEN TEMPERATURE – ASSOCIATED WITH SPECIMEN 1




FIGURE 4 – SPECIMEN TEMPERATURE – ASSOCIATED WITH SPECIMEN 2




FIGURE 5 – SPECIMEN TEMPERATURE – ASSOCIATED WITH SPECIMEN 3




FIGURE 6 – SPECIMEN TEMPERATURE – ASSOCIATED WITH SPECIMEN 4





FIGURE 7 – SPECIMEN TEMPERATURE – ASSOCIATED WITH SPECIMEN 5

Appendix D – Installation drawings

Snap Fire Systems Pty Ltd
 Test Slab S-19-D Layout
 Date: 08 MAY 2019



Penetration	Collar Code	Pipe Type	Pipe Diameter (mm)	Fitting
1	H50S	PVC	50	N/A
2	H65S	PVC	65	N/A
3	H100S	PVC	100	N/A
4	H50S	Triplus	50	N/A
5	H50S	Triplus	40	N/A


DRAWING TITLED "TEST SLAB S-19-D LAYOUT", DATED 8 MAY 2019, PROVIDED BY SNAP FIRE SYSTEMS PTY LTD

Snap Fire Systems Pty Ltd

Specimen #1

50 PVC Stack & H50S-RR

Date: 15 MAY 2019




DRAWING "SPECIMEN #1, 50 PVC STACK & H50S-RR", DATED 15 MAY 2019, PROVIDED BY SNAP FIRE SYSTEMS PTY LTD

Snap Fire Systems Pty Ltd

Specimen #2

65 PVC Stack & H65S-RR

Date: 15 MAY 2019




DRAWING TITLED "SPECIMEN # 2, 65 PVC STACK & H65S-RR", DATED 15 MAY 2019, PROVIDED BY NAP FIRE SYSTEMS PTY LTD

Snap Fire Systems Pty Ltd

Specimen #3

100 PVC Stack & H100S-RR

Date: 15 MAY 2019




DRAWING TITLED "SPECIMEN # 3, 100 PVC STACK & H100R-SS", DATED 15 MAY 2019, PROVIDED BY SNAP FIRE SYSTEMS PTY LTD

Snap Fire Systems Pty Ltd

Specimen #4

50 Triplus Stack & H50S-RR

Date: 15 MAY 2019




**DRAWING TITLED "SPECIMEN #4, 50 TRIPLUS STACK & H50S-RR", DATED 15 MAY 2019,
PROVIDED BY SNAP FIRE SYSTEMS PTY LTD**

Snap Fire Systems Pty Ltd

Specimen #5


40 Triplus Stack & H50S-RR

Date: 15 MAY 2019




DRAWING TITLED "SPECIMEN #5, 40 TRIPLUS STACK & H50S-RR", DATED 15 MAY 2019, PROVIDED BY SNAP FIRE SYSTEMS PTY LTD

Appendix E – Specimen Drawings




DRAWING NUMBER H100S-RR-T, DATED 29 SEPTEMBER 2017, BY SNAP FIRE SYSTEMS PTY LTD.




TITLE		SNAP 65 High-Top Stack	
DWG NO.	H65S-RR	SCALE	A4
DO NOT SCALE DRAWING		TEST	2
DATE		29/09/2017	

Product Information including Installation Instructions and full test reports are available at www.snapcollars.com.au

SNAP FIRE SYSTEMS
 1343 Wynnum Rd, Tingalpa, QLD, 4173, Australia
 ☎ 1300 76 46 26
 📠 +61 (0)7 3390 5420
 📧 +61 (0)7 3348 9417
 ✉ info@snapcollars.com.au
www.snapcollars.com.au



DRAWING NUMBER H65S-RR-T, DATED 29 SEPTEMBER 2017, BY SNAP FIRE SYSTEMS PTY LTD.



DRAWING NUMBER H50S-RR-T, DATED 29 SEPTEMBER 2017, BY SNAP FIRE SYSTEMS PTY LTD.

Appendix F – Certificate(s) of Test

INFRASTRUCTURE TECHNOLOGIES www.csiro.au		
14 Julius Avenue, North Ryde NSW 2113 PO Box 52, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230		
<h2>Certificate of Test</h2>		No. 3286
This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014, Section 10: Service penetrations and control joints, on behalf of:		
IG6 Pty Ltd as trustee for the IG6 IP Trust 3 Skirmish Court Victoria Point Qld 4165		
A full description of the test specimen and the complete test results are detailed in the Division's report numbered FSP 2016.		
Product Name: SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polyvinyl chloride (PVC-U) stack pipe (Specimen 1)		
Description:	The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by a stack pipe protected by a Snap Fire System Cast-in Snap Fire Systems fire collar. The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures. The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67 mm inner diameter and a 150-mm diameter base flange. The 250 mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 55.85-mm outside diameter polyvinyl chloride pipe with a wall thickness of 2.23 mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #1, 50 PVC Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500 mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap on the exposed end.	
Performance observed in respect of the following AS 1530.4-2014 criteria		
	Structural Adequacy	- not applicable
	Integrity	- no failure at 241 minutes
	Insulation	- 177 minutes
and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120.		
The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested. The fire-resistance level (FRL) is limited to that of the separating element. For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.		
Testing Officer:	Peter Gordon	Date of Test: 26 June 2019
Issued on the 19 th day of August 2019 without alterations or additions.		
 Brett Roddy Manager, Fire Testing and Assessments		
"Copyright CSIRO 2019 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden		
	This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025 - Testing	

COPY OF CERTIFICATE OF TEST – NO. 3286



Certificate of Test

No. 3287

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014, Section 10: Service penetrations and control joints, on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
 3 Skirmish Court
 Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's report numbered FSP 2016.

Product Name: SNAP H65S-RR Cast-in collar protecting a nominal 65-mm polyvinyl chloride (PVC-U) stack pipe (Specimen 2)

Description: The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by a stack pipe protected by a Snap Fire System Cast-in Snap Fire Systems fire collar. The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures. The SNAP Cast-in H65S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 79 mm inner diameter and a 168-mm diameter base flange. The 250 mm high collar casing incorporated a 280-mm x 65-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 322-mm x 65-mm 304 stainless steel mesh as shown in drawing numbered H65S RR-T dated 29 September 2015, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 68.68-mm outside diameter polyvinyl chloride pipe with a wall thickness of 2.85 mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #2, 65 PVC Stack & H65S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500 mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap on the exposed end.

Performance observed in respect of the following AS 1530.4-2014 criteria

Structural Adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	184 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120.

The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested. The fire-resistance level (FRL) is limited to that of the separating element. For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Peter Gordon Date of Test: 26 June 2019

Issued on the 19th day of August 2019 without alterations or additions.

Brett Roddy | Manager, Fire Testing and Assessments

"Copyright CSIRO 2019 ©"

Copying or alteration of this report without written authorisation from CSIRO is forbidden



This document is issued in accordance with NATA's accreditation requirements.
 Accreditation No. 165 – Corporate Site No. 3625
 Accredited for compliance with ISO/IEC 17025 - Testing



Certificate of Test

No. 3288

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014, Section 10: Service penetrations and control joints, on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
3 Skirmish Court
Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's report numbered FSP 2016.

Product Name: SNAP H1005-RR Cast-in collar protecting a nominal 110-mm polyvinyl chloride sandwich construction (PVC-SC) stack pipe (Specimen 3)

Description: The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by a stack pipe protected by a Snap Fire System Cast-in Snap Fire Systems fire collar. The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures. The SNAP Cast-in H1005-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 126.5-mm inner diameter and a 213-mm diameter base flange. The 250 mm high collar casing incorporated a 412-mm x 85-mm x 4-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three equally spaced 3.15-mm diameter galvanised steel springs bound with nylon fuse links acting against a 460-mm x 83-mm 316 stainless steel mesh as shown in drawing numbered H1005 RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 110-mm outside diameter polyvinyl chloride sandwich construction pipe with a wall thickness of 3.4-mm fitted through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #3, 110 Triplus Stack & H1005-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a PVC end cap.

Performance observed in respect of the following AS 1530.4-2014 criteria

Structural Adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	148 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120.

The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested. The fire-resistance level (FRL) is limited to that of the separating element. For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Peter Gordon Date of Test: 26 June 2019

Issued on the 19th day of August 2019 without alterations or additions.

Brett Roddy | Manager, Fire Testing and Assessments

"Copyright CSIRO 2019 ©"

Copying or alteration of this report without written authorisation from CSIRO is forbidden



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing



Certificate of Test

No. 3289

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014, Section 10: Service penetrations and control joints, on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
 3 Skirmish Court
 Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's report numbered FSP 2016.

Product Name: SNAP H50S-RR Cast-in collar protecting a nominal 50-mm polypropylene (Valsir Triplus) stack pipe (Specimen 4)

Description: The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by a stack pipe protected by a Snap Fire System Cast-in Snap Fire Systems fire collar. The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures. The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67 mm inner diameter and a 150-mm diameter base flange. The 250 mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 49.6-mm outside diameter polypropylene pipe with a wall thickness of 2.29 mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #4, 50 Triplus Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a Superwool plug on the exposed end.

Performance observed in respect of the following AS 1530.4-2014 criteria

Structural Adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	179 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120.

The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested. The fire-resistance level (FRL) is limited to that of the separating element. For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Peter Gordon Date of Test: 26 June 2019

Issued on the 19th day of August 2019 without alterations or additions.

Brett Roddy | Manager, Fire Testing and Assessments

"Copyright CSIRO 2019 ©"

Copying or alteration of this report without written authorisation from CSIRO is forbidden



This document is issued in accordance with NATA's accreditation requirements.
 Accreditation No. 165 – Corporate Site No. 3625
 Accredited for compliance with ISO/IEC 17025 - Testing



Certificate of Test

No. 3290

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014, Section 10: Service penetrations and control joints, on behalf of:

IG6 Pty Ltd as trustee for the IG6 IP Trust
 3 Skirmish Court
 Victoria Point Qld 4165

A full description of the test specimen and the complete test results are detailed in the Division's report numbered FSP 2016.

Product Name: SNAP H50S-RR Cast-in collar protecting a nominal 40-mm polypropylene (Valsir Triplus) stack pipe (Specimen 5)

Description: The specimen comprised an 1150-mm x 1150-mm x 120-mm thick concrete slab penetrated by a stack pipe protected by a Snap Fire System Cast-in Snap Fire Systems fire collar. The penetrated slab comprised a 120-mm thick concrete slab reinforced with a single layer of steel reinforcement providing a Fire Resistance Period (FRP) for insulation of 120 minutes in accordance with table 5.5.1 of AS 3600:2018 - Concrete Structures. The SNAP Cast-in H50S-RR fire collar comprised a 1.6-mm thick polypropylene casing with a 67 mm inner diameter and a 150-mm diameter base flange. The 250 mm high collar casing incorporated a 230-mm x 55-mm x 5-mm thick Intumesh intumescent material and a rubber ring seal. The closing mechanism comprised three galvanised steel springs bound with nylon fuse links and a 268-mm x 53-mm 316 stainless steel mesh as shown in drawing numbered H50S RR-T dated 29 September 2017, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 40-mm outside diameter polypropylene pipe with a wall thickness of 2.32 mm through the collar's sleeve. The annular gap between the pipe and the inside collar was protected with a bead of Fullers Firesound sealant as shown in drawing titled "Specimen #5, 40 Triplus Stack & H50S-RR", dated 15 May 2019, provided by Snap Fire Systems Pty Ltd. The pipe projected vertically, 2000-mm above from the unexposed face of the concrete slab and 500-mm into the furnace chamber. The pipe was supported at nominally 500-mm and 1500-mm from the unexposed face of the slab. The pipe was open at the unexposed end and closed with a Superwool plug on the exposed end.

Performance observed in respect of the following AS 1530.4-2014 criteria

Structural Adequacy	-	not applicable
Integrity	-	no failure at 241 minutes
Insulation	-	196 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120.

The fire-resistance level of the specimen is applicable when the system is exposed to fire from the same direction as tested. The fire-resistance level (FRL) is limited to that of the separating element. For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Peter Gordon Date of Test: 26 June 2019

Issued on the 19th day of August 2019 without alterations or additions.

Brett Roddy | Manager, Fire Testing and Assessments

"Copyright CSIRO 2019 ©"

Copying or alteration of this report without written authorisation from CSIRO is forbidden



This document is issued in accordance with NATA's accreditation requirements.
 Accreditation No. 165 – Corporate Site No. 3625
 Accredited for compliance with ISO/IEC 17025 - Testing

References

The following informative documents are referred to in this Report:

- | | |
|----------------|---|
| AS 1530.4-2014 | Methods for fire tests on building materials, components and structures Part 4: Fire-resistance tests of elements of building construction. |
| AS 4072.1-2005 | Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints. |
| AS 3600-2018 | Concrete structures |

CONTACT US

t 1300 363 400
+61 3 9545 2176
e enquiries@csiro.au
w www.csiro.au

YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

FOR FURTHER INFORMATION

Infrastructure Technologies

Brett Roddy
Team Leader, Fire Testing and Assessments
t +61 2 94905449
e brett.rodny@csiro.au
w <https://www.csiro.au/en/Do-business/Services/Materials-infrastructure/Fire-safety>